



2012 Annual Drinking Water Quality Report

For

City of Worland

PO Box 816

Worland WY 82401

(307) 347-8978

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of two artesian wells drawn from the Madison formation.

I am pleased to report to our consumers that our drinking water is **safe** and meets **Federal** and **State** requirements.

If you have any questions about this report or concerning your water utility, please contact **Gary Thompson at (307) 347-8978**. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on **the first and third Tuesday of each month. The meetings are located at the Worland City Hall at 7:00 PM.**

City of Worland routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, **2012**. As water travels over the land or underground it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

You can obtain a copy of our source water assessment from City Hall at 829 Big Horn Ave.

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference – try one today and soon it will become second nature.

- _ Take short showers – a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- _ Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- _ Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- _ Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- _ Water plants only when necessary.
- _ Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check

your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.

- _ Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- _ Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!

The purpose of a Cross Connection Control Survey is to determine whether a cross-connect may exist at your home or business. A cross connection is an unprotected or improper connection to a public water distribution system that may cause contamination or pollution to enter the system. We are responsible for enforcing cross-connection control regulations and insuring that no contaminants can, under any flow conditions, enter the distribution system. If you have any of the devices listed below please contact us so that we can discuss the issue, and if needed, survey your connection and assist you in isolating it if that is necessary.

- _ Boiler/Radiant heater (water heaters not included)
- _ Underground lawn sprinkler system
- _ Pool or hot tub (whirlpool tubs not included)
- _ Additional source(s) of water on the property
- _ Decorative pond
- _ Watering trough

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the laboratory does not detect the constituent.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/l) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) or Picograms per liter (picograms/l) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Million Fibers per Liter (MFL) - million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Variances & Exemptions (V&E) - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - (mandatory language) A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - (mandatory language) The “Maximum Allowed” (MCL) is the highest level of a contaminant that is allowed in drinking water. MCL’s are set as close to the MCLG's as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - (mandatory language) The “Goal”(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

Maximum residual disinfectant level goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum residual disinfectant level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Not Applicable – (N/A) Not applicable means that this constituent was not requested by the EPA for monitoring.

TEST RESULTS						
Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants						
1. Total Coliform Bacteria	N	Negative	N/A	0	Presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment
2. Fecal Coliform and <i>E.coli</i>	N	ND	CFU/100 ml	0	a routine sample and repeat sample are total coliform positive, and one is also fecal coliform or <i>E. coli</i> positive	Human and animal fecal waste
3. Turbidity	N/A	N/A	NTU	N/A	TT	Soil runoff
Radioactive Contaminants						
4. Beta/photon emitters	N/A	N/A	Mrem/yr	0	4	Decay of natural and man-made deposits
5. Alpha emitters	N	1.4	pCi/l	0	15	Erosion of natural deposits
6. Combined radium	N	0.4	pCi/l	0	5	Erosion of natural deposits
Inorganic Contaminants						

TEST RESULTS						
Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
7. Antimony	N	ND	ppb	6	6	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
8. Arsenic	N	ND	ppb	N/A	50	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
9. Asbestos	N/A	N/A	MFL	7	7	Decay of asbestos cement water mains; erosion of natural deposits
10. Barium	N	ND	ppb	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
11. Beryllium	N	ND	ppb	4	4	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
12. Cadmium	N	ND	ppb	5	5	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
13. Chromium	N	ND	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper (Source)	N	ND	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
14A. Copper (Pb&Cu Rule/Tap Monitoring)(2011)	N	0.83	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
15. Cyanide	N	ND	ppb	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
16. Fluoride	N	0.28	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead (Source)	N	ND	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
17. Lead (Pb&Cu Rule/Tap Monitoring)(2011)	N	3	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
18. Mercury (inorganic)	N	ND	ppb	2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland

TEST RESULTS						
Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
19. Nitrate (as Nitrogen) (2011)	N	0.5	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
20. Nitrite (as Nitrogen)	N	ND	ppm	1	1	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
21. Selenium	N	ND	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
21A. Sodium(2010)	N	2.7	ppm	None	None	Natural occurring
22. Thallium	N	ND	ppb	0.5	2	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories
Synthetic Organic Contaminants including Pesticides and Herbicides						
23. 2,4-D	N	ND	ppb	70	70	Runoff from herbicide used on row crops
24. 2,4,5-TP (Silvex)	N	ND	ppb	50	50	Residue of banned herbicide
25. Acrylamide	N	ND	ppb	0	TT	Added to water during sewage/wastewater treatment
26. Alachlor	N	ND	ppb	0	2	Runoff from herbicide used on row crops
27. Atrazine	N	ND	ppb	3	3	Runoff from herbicide used on row crops
28. Benzo(a)pyrene (PAH)	N	ND	Nanograms/l	0	200	Leaching from linings of water storage tanks and distribution lines
29. Carbofuran	N	ND	ppb	40	40	Leaching of soil fumigant used on rice and alfalfa
30. Chlordane	N	ND	ppb	0	2	Residue of banned termiticide
31. Dalapon	N	ND	ppb	200	200	Runoff from herbicide used on rights of way
32. Di(2-ethylhexyl) adipate	N	ND	ppb	400	400	Discharge from chemical factories
33. Di(2-ethylhexyl) phthalate	N	ND	ppb	0	6	Discharge from rubber and chemical factories
34. Dibromochloropropane	N	ND	Nanograms/l	0	200	Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards
35. Dinoseb	N	ND	ppb	7	7	Runoff from herbicide used on soybeans and vegetables
36. Diquat	N	ND	ppb	20	20	Runoff from herbicide use

TEST RESULTS						
Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
37. Dioxin [2,3,7,8-TCDD]	N/A	N/A	Picograms/l	0	30	Emissions from waste incineration and other combustion; discharge from chemical factories
38. Endothall	N	ND	ppb	100	100	Runoff from herbicide use
39. Endrin	N	ND	ppb	2	2	Residue of banned insecticide
40. Epichlorohydrin	N	ND	ppb	0	TT	Discharge from industrial chemical factories; an impurity of some water treatment chemicals
41. Ethylene dibromide	N	ND	Nanograms/l	0	50	Discharge from petroleum refineries
42. Glyphosate	N	ND	ppb	700	700	Runoff from herbicide use
43. Heptachlor	N	ND	Nanograms/l	0	400	Residue of banned termiticide
44. Heptachlor epoxide	N	ND	Nanograms/l	0	200	Breakdown of heptachlor
45. Hexachlorobenzene	N	ND	ppb	0	1	Discharge from metal refineries and agricultural chemical factories
46. Hexachlorocyclopentadiene	N	ND	ppb	50	50	Discharge from chemical factories
47. Lindane	N	ND	Nanograms/l	200	200	Runoff/leaching from insecticide used on cattle, lumber, gardens
48. Methoxychlor	N	ND	ppb	40	40	Runoff/leaching from insecticide used on fruits, vegetables, alfalfa, livestock
49. Oxamyl [Vydate]	N	ND	ppb	200	200	Runoff/leaching from insecticide used on apples, potatoes and tomatoes
50. PCBs [Polychlorinated biphenyls]	N	ND	Nanograms/l	0	500	Runoff from landfills; discharge of waste chemicals
51. Pentachlorophenol	N	ND	ppb	0	1	Discharge from wood preserving factories
52. Picloram	N	ND	ppb	500	500	Herbicide runoff
53. Simazine	N	ND	ppb	4	4	Herbicide runoff
54. Toxaphene	N	ND	ppb	0	3	Runoff/leaching from insecticide used on cotton and cattle
Volatile Organic Contaminants						
55. Benzene	N	ND	ppb	0	5	Discharge from factories; leaching from gas storage tanks and landfills
56. Carbon tetrachloride	N	ND	ppb	0	5	Discharge from chemical plants and other industrial activities

TEST RESULTS						
Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
57. Chlorobenzene	N	ND	ppb	100	100	Discharge from chemical and agricultural chemical factories
58. o-Dichlorobenzene	N	ND	ppb	600	600	Discharge from industrial chemical factories
59. p-Dichlorobenzene	N	ND	ppb	75	75	Discharge from industrial chemical factories
60. 1,2 - Dichloroethane	N	ND	ppb	0	5	Discharge from industrial chemical factories
61. 1,1 – Dichloroethylene	N	ND	ppb	7	7	Discharge from industrial chemical factories
62. cis-1,2- Dichloroethylene	N	ND	ppb	70	70	Discharge from industrial chemical factories
63. trans - 1,2 – Dichloroethylene	N	ND	ppb	100	100	Discharge from industrial chemical factories
64. Dichloromethane	N	ND	ppb	0	5	Discharge from pharmaceutical and chemical factories
65. 1,2-Dichloropropane	N	ND	ppb	0	5	Discharge from industrial chemical factories
66. Ethylbenzene	N	ND	ppb	700	700	Discharge from petroleum refineries
67. Styrene	N	ND	ppb	100	100	Discharge from rubber and plastic factories; leaching from landfills
68. Tetrachloroethylene	N	ND	ppb	0	5	Leaching from PVC pipes; discharge from factories and dry cleaners
69. 1,2,4 – Trichlorobenzene	N	ND	ppb	70	70	Discharge from textile-finishing factories
70. 1,1,1 - Trichloroethane	N	ND	ppb	200	200	Discharge from metal degreasing sites and other factories
71. 1,1,2 –Trichloroethane	N	ND	ppb	3	5	Discharge from industrial chemical factories
72. Trichloroethylene	N	ND	ppb	0	5	Discharge from metal degreasing sites and other factories
73. TTHM [Total trihalomethanes]	N	ND	ppb	0	100	By-product of drinking water chlorination
74. Toluene	N	ND	ppm	1	1	Discharge from petroleum factories
75. Vinyl Chloride	N	ND	ppb	0	2	Leaching from PVC piping; discharge from plastics factories
76. Xylenes	N	ND	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories
Disinfectants and Disinfection Byproducts						
TTHM (Total trihalomethanes)(2011)	N	1.77	ppb	N/A	80	By-product of drinking water chlorination

TEST RESULTS						
Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
HAA5 (Haloacetic Acids)	N	0.27	ppb	N/A	60	By-product of drinking water chlorination

What does this mean?

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that your water IS SAFE at these levels.

Some of our data in the tables are more than one year old, since certain chemical contaminants are monitored less than once a year. Our sampling frequency complies with EPA drinking water regulations.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it can dissolve naturally occurring minerals and, in some cases, radioactive materials. The water can also pick up substances such as:

- 1) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural operations and wildlife.
- 2) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic waste water discharges, oil and gas production, mining or farming.
- 3) Pesticides and Herbicides, which may come from agriculture, urban storm water runoff, and residential uses.
- 4) Organic chemical contaminants, which can come from industrial processes, gas stations, urban storm water runoff and septic systems.
- 5) Radioactive contaminants, which can be naturally occurring or the result of oil and gas production and mining activities.

In order to insure that tap water is safe to drink, EPA establishes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for human health.

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink a half gallon of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791) or EPA (800-227-8917).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Worland is responsible for providing high quality drinking water, but cannot control the

variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://ww.epa.gov/safewater/lead>.

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- _ Eliminate excess use of lawn and garden fertilizers and pesticides – they contain hazardous chemicals that can reach your drinking water source.
- _ Pick up after your pets.
- _ If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- _ Dispose of chemicals properly; take used motor to a recycling center.
- _ Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
- _ Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste – Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

We at the City of Worland work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.